

CITY OF MORRO BAY

EXTENSION CORD REQUIREMENTS

1. All extension cords (marine shore power cable sets) must be of a minimum 30 ampere rating of minimum 10 gauge wire with locking and grounding type receptacle ends rated at not less than 30 amperes.
2. Flexible cords shall be outdoor use Type 5, SO, 500, ST, STO, STOO, SE, SEO, SJ, SJO, SJOO, SJT, SJTO, SJTOO, SJE, OR SJEO and be further identified as "W-A" or "Water Resistant" in construction. (These ratings are stamped every 24" on the cord insulation cover.)
3. Only unmodified, manufactured cord sets or adapters that have not been altered to defeat the intended blade and slot configuration are acceptable. Adapters must meet the same requirements for load rating and receptacles as extension cords.
4. Splicing of extension cords and use of frayed or damaged extension cords is prohibited.