


GENERAL NOTES:

- A. A depression in a new curb and gutter for a driveway will not be permitted unless the ramp and sidewalk extension are constructed also.
- B. Slope of ramp is a straight grade from the top of the back of ramp to the top of the lip at the gutter.
- C. Concrete Class II 2500 psi
- D. Dowels at expansion or cold joint with new construction shall be 1/2" smooth bars, 15" long at 24" O.C., one end shall be sleeved or greased.
- E. All ramps and sidewalk shall be reinforced with rebar, #4 @ 24" O.C., continuous both ways. Rebar shall run continuous through cold or expansion joints.
- F. Commercial and industrial driveways ramps serving more than six (6) parking spaces shall be 10' deep (long) unless otherwise approved by the City Engineer.
- G. Required 18" min. /10' max. AC cut and pave back to competent material.
- H. Residential driveway widths: 10' min. /20 max., Commercial widths: 12' min. (one-way) and 20' (two-way)/30 max.
 - I. If right of way is more than 10' from curb face, back of sidewalk extension shall not extend beyond 10' from curb face.
 - J. Compaction test required for driveways.
 - K. No part of driveway transition shall extend closer than one foot to the side property line of property being served by the driveway.

REVISIONS	BY	APP	DATE
STANDARD CURRENT AS OF:			



DRIVEWAY WITH SIDEWALK

STANDARD

B-6